

Question 16. *Provide copies of all excess emission reports and Title V deviation reports for this facility from 2005 to the date of this request.*

As required by 40 CFR 60, Intermountain Power Service Corporation (IPSC) prepares and submits the Intermountain Power Project's (IPP's) Excess Emission Reports (EERs) on a quarterly basis to the Utah Division of Air Quality (UDAQ) in an electronic format as required by UAC R307-170-9. UDAQ calls this format a "State Electronic Data Report (SEDR)." IPSC also submits a certification letter to the UDAQ for the SEDR.

IPSC is also required to submit all Title V Deviation Reports to the UDAQ. The only deviations IPP has had from 2005 to present reflect those occasions when the opacity has been greater than 20 percent as measured by the continuous opacity monitors. The opacity deviations are included in and reported in the quarterly EER IPSC submits to the UDAQ. IPSC also submits a certification letter to the UDAQ for the Deviation Reports.

The quarterly SEDR that IPSC submits to the UDAQ includes both the EER and the Deviation Reports.

Included in this response are copies of each of the SEDR reports submitted to the UDAQ from 2005 to the present. Also included are copies of the submittal and certification letters and the acknowledgment responses from the UDAQ for the quarterly SEDR which includes the EER and Deviation Reports. In the process of reviewing the documents for this response, IPSC could not find a copy of the letter from the UDAQ acknowledging the Third Quarter 2009. The UDAQ provided IPSC an unsigned copy of this letter.

This response was prepared by IPSC employee Blaine Ipson. Mike Ferrell, Lynn Banks, Rand Crafts, and Brook Pace were consulted in preparing this response.